

INSTRUCTION MANUAL

12 kV Non-Destructive
Insulation Tester

Type JP12

Instructions for use1. Supply voltage

Check that the switch at the back of the instrument is correctly set and that the correct fuse is fitted.

2. Earthing

The instrument must - if at all possible - be earthed in order to suppress random noise and hum voltages in the test circuit. Connect the earth lead to the earth terminal on the front panel.

3. Connection of test sample

Connect one terminal of the sample to the earth terminal. The test prod applies the H.T. test voltage to the other terminal.

4. Apply mains voltage

by employing the power switch. The green pilot lamp indicates mains voltage switched on. After about one minute, the valves have heated up, and the instrument is ready for use.

5. Testing procedure

The settings of "Amplifier Gain" and "H.T. Control" should be in minima positions. Set switch "6kV - 12kV" in "6kV" position. Take the H.T.-test prod on the flexible cable and keep it in touch with the other terminal or test point of the item.

The conical test prod is terminated in a straight shank section for fixing a crocodile clip.

The "Amplifier Gain" control is turned up to a suitable position. Press the handle spring contact, this switches on the H.T. as indicated by the red lamp lighting up.

Increase the H.T. gradually by turning the H.T. control up and check the voltage and leakage currents on the meters.

The noise emitted from the loudspeaker as the applied voltage rises constitutes a "noise picture" which may be employed for evaluating the characteristics and performance of the insulation.

Ionisation Phenomena do not show a well defined threshold value, but, will commence accordingly to material constants, surface nature, measuring conditions e.g. temperature, air humidity etc. But, within a series of tests and by noticing measuring conditions one may obtain a good comparable and reproducible indication of the material tested. Therefore, a good experience and routine tests with this instrument, in each particular case, will make an outstanding help in the judgement of insulation materials.

The ionisation current flow produces a characteristic noise signal in the loudspeaker, usually beginning with a hissing noise. On increasing the H.T. the hiss will become more intense and distinct and, when going on more sharp clicks are heard. If the test voltage is made great enough the break-down limit of the material is reached. This causes the H.T. meter pointer deflection to decrease as the leakage current rises. Simultaneously a number of cracks in rapid successions are heard on the loudspeaker until at complete break-down the crack pulses finally cease.

For many production control tests the break-down test is usually of no interest, but the determination of ionisation "limit" solves many material problems. The break-down test, however, is of more interest in the laboratory during the design stages when the break-down limit must be known.

The switch "6kV - 12kV" controls the H.T. range and when switching from the lower to the higher range the H.T. control must be turned anticlockwise in order to avoid a sudden voltage rise on the test sample.

If remote operation of the H.T. relay is required e.g. when employing a safety cage the spring contact function in the handle may be replaced by applying an external switch to the coaxial connector "EXT.H.T.Switch". The external switch is connected between pin 2 and shield on the plug connector. The ext. switch may e.g. be a foot operated type. The relay operating voltage is only 6.3 V a-c.

NOTE When reducing the H.T. setting from a high value to a much lower value with the H.T. switch off, wait for at least 10 seconds before operating the H.T. switch. If the delay is too short a momentary surge voltage develops which may destroy the test object.

6. Internal Resistance

The internal resistance of the H.T. source is about 10 Megohms and provides a safe current limitation in testing procedure as well as reducing the personal risk to a minimum.

WARNING! When testing large capacitors (over ab. 1000 pF) take care of the charging voltage and short circuit the capacitor through a resistor after testing.

7. Testing insulation resistance

The insulation resistance of many materials tends to vary according to the test voltage and often too to the polarisation of the voltage applied. The insulation resistance value may be calculated from the test voltage and leakage current reading.

8. Use of phone

A headphone or c-r oscilloscope may be employed as indicator e.g. in noisy locations. The external indicator is connected between pin 2 and shield on the 4-pin plug connector. When phones are used, the instrument should always be carefully grounded and the operator must keep away from any high tension points.

Circuit Description

The circuit comprises the H.T. circuit, a 3-stage amplifier and the power supply.

H.T. unit. This consists of a 20kc-oscillator employing an output pentode tube as oscillator. A secondary winding on the tuning coil supplies a high alternating voltage. This is rectified by a vacuum diode.

The rectified d-c after filtering is fed to the test-prod. A chain of resistors totalling 60 M Ω connects the H.T. to the 100 μ A monitorvoltmeter. On the 12 kV range the meter is shunted to 200 μ A fullscale.

Leakage current is monitored by a 100 μ A meter in the negative H.T. lead. A silicon diode is shunted across the meter to avoid damage to the meter due to short-circuits in the test-object.

The noise voltage due to ionisation in the test object is coupled to the amplifier through a 500 pF capacitor connected to the H.T. test lead. The complete H.T. unit is built into a dust-tight box to ensure reliable operation for long periods.

Amplifier. The amplifier input is shunted by a voltage-sensitive resistor which limits the input to the amplifier to a safe value in case of short-circuits in the test object.

A low-pass filter in the input circuit and a tuned rejector circuit in the cathode lead of the first amplifier stage are employed to avoid amplifier overloading due to oscillator voltage break-through.

The amplifier comprises 3 stages with a gain control between the first and second stage. The output feeds a crystaltype loudspeaker to give an audible indication of noise.

Power Supply The power transformer may be switched to either 110 or 220 volts by connecting the primary windings either in parallel or in series.

3 separate secondary windings of 140 volts each supply bridge-connected silicon rectifiers with capacitor outputs. Two of the outputs are connected in series and provide a positive supply of about 350 to 400 volts according to load. The third rectifier output provides a 150 volt negative bias.

The high tension voltage is adjusted by varying the supply voltages for the oscillator tube. These are controlled by a series regulator tube fed from the positive 400 volt supply.

The output voltage from the series regulator is controlled by varying the bias on the control grid by means of a potentiometer ("H.T. control"). The low end of this potentiometer is connected to the auxillary negative supply to enable reducing the test voltage right down to zero.

Anode voltage for the amplifier is supplied at about 200 volts by one of the rectifier outputs.

Maintenance and Service

All critical components in the H.T. unit are hermetically encapsulated so that the instrument is suitable for operation even in humid environments. However, in case of prolonged exposure to high humidity during storage or transport it is adviseable to operate the instrument for one or two days continuously with high tension switched off in order to eliminate any absorbed moisture.

Before dismantling the instrument, disconnect the mains supply.

Loosen the 4 screws holding the front panel. Turn instrument upside down, remove the 4 screws holding the bottom cover and remove this.

Remove the top cover by pulling the lower side panels outwards until the cover front-edge is clear of the front panel upper fixing screws. Then lift cover away.

Fasten front panel screws lightly to ensure that the control knobs are free of the front panel.

To reassemble the instrument, put on the top and bottom covers and fasten the bottom cover screws lightly. Then adjust the front panel frame so that it is flush with the top cover on all sides and tighten the top screws in the front panel.

With the instrument upside down, center the bottom cover and tighten the bottom front panel screws while pressing the front edge of the bottom cover down. Finally tighten the bottom cover screws.

Access to the H.T. unit is gained by removing the lid of the screening box.

In order to remove the complete H.T. unit, pull off the connector socket and remove the four fixing screws.

A/s DANBRIDGE

47 Brigadevej . Copenhagen S . Denmark

If the H.T. oscillator coil or the complete unit has been replaced, re-adjustment of the rejector circuit in the amplifier input may be necessary.

In order to check this adjustment connect a c-r oscilloscope to the phone output, set the gain control to maximum and the H.T. output to about 6kV. Adjust the preset trimmer (500 - 2000 pF) in the rejector circuit until minimum 20 kc output is obtained, as indicated on the c-r screen.

LIST OF COMPONENTS

The components are grouped according to the respective sub-units as listed below.

1. Power supply printed circuit board.
2. H.T. generator unit.
3. Amplifier printed circuit board.
4. Front panel components.
5. Rear panel components.
6. Test prod and miscellaneous.

1. POWER SUPPLY BOARD

Complete assembly excluding V3, Part No. 89050

Capacitors

Circuit Ref.	Value	Rating V	Tol. %	Manufacturer	Type	Part No.
C8	0.2 μ F	600	20%	Philips	metal.plastic	40460
C9	50 μ F	350	-10 +50	Philips	Electrolyt.	40904
C10	50 μ F	350	-10 +50	Philips	Electrolyt.	40904
C11	50 μ F	350	-10 +50	Philips	Electrolyt.	40904
C12	50 μ F	350	-10 +50	Philips	Electrolyt.	40904

Resistors

Circuit Ref.	Value	Rating	Tol. %	Manufacturer	Type	Part No.
R8	*33K Ω	1W	5	Beyschlag	Carbon	45333
R11	1M Ω	1W	5	Beyschlag	Carbon	45510
R12	1K Ω	1/3W	5	Beyschlag	Carbon	43210
R13	1K Ω	1/3W	5	Beyschlag	Carbon	43210
R14	33K Ω	10W	5	Philips	WW	46260
R15	15K Ω	1W	5	Beyschlag	Carbon	45315
R16	1K Ω	1/3W	5	Beyschlag	Carbon	43210
R17	100K Ω	1/3W	5	Beyschlag	Carbon	43410
R18	4.7K Ω	1/3W	5	Beyschlag	Carbon	43247

* R8 is adjusted on test.

A/s DANBRIDGE

47 Brigadevej . Copenhagen S . Denmark

Miscellaneous

	Part No.
Rec. 3 Bridge rectifier Philips Type BY123	26251
Rec. 4 Bridge rectifier Philips Type BY123	26251
Rec. 5 Bridge rectifier Philips Type BY123	26251
Rel. Relay 6,3V AC Keyswitch Type MK2	53630
Tube socket Octal for P.C. Jungbecker 845	25413
V3 Pentode output tube EL36, Philips, Mullard	54100

2. H.T. GENERATOR UNIT

Complete assembly excluding V2 Part No. 81800

Capacitors

Circuit Ref.	Value	Rating	Tol. %	Manufacturer	Type	Part No.
C1	500pF	20kV	-20 +60	L.C.C.	Ceramic	39500
C2	500pF	20kV	-20 +60	L.C.C.	Ceramic	39500
C3	500pF	20kV	-20 +60	L.C.C.	Ceramic	39500
x C4	2.5μF	64V	-10 +50	Philips	Electrolyt	40810
x C5	2.5μF	64V	-10 +50	Philips	Electrolyt	40810
x C6	4.7nF	500V	-20 +50	Philips	Ceramic	40150
x C7	0.1μF	400V	20	Philips	metal.plastic	40730
x C14	0.1μF	400V	20	Philips	metal.plastic	40730

Resistors

Circuit Ref.	Value	Rating	Tol. %	Manufacturer	Type	Part No.
R1	1MΩ	1W	5	Beyschlag	Carbon	45510
R2	1MΩ	1W	5	Beyschlag	Carbon	45510
R3	60MΩ		5	Danbridge	Special	
Alternatively						
R3	2 x 30MΩ	1W	5	Welwyn	Metal.	46261
x R4	100kΩ	1/3W	5	Beyschlag	Carbon	43410
x R5	47kΩ	1/3W	5	Beyschlag	Carbon	43347
x R6	10kΩ	1/3W	5	Beyschlag	Carbon	43310
x R7	1MΩ	1/3W	5	Beyschlag	Carbon	43510

A/s DANBRIDGE

47 Brigadevej . Copenhagen S . Denmark

Miscellaneous

<u>Circuit Ref.</u>		<u>Part No</u>
x L1	Filter choke 10mH Manufacturer Prahm	42800
x Rec.1	Germanium diode OA81 Philips, Mullard	26100
T1	Fil. Transformer J. Schou	61004
	(H.T. Coil	92550
T2	H.T. Transformer Danbridge (Grid Coil	92551
	(U-core set	36110
V1	H.T. Rectifier tube DY87, Telefunken	54300
V2	Output pentode EL36, Philips, Mullard	54100
Printed circuit board incorporating components above marked x		89052

3. AMPLIFIER BOARD

Complete assembly excluding V4, V5 and V6, Part No. 89051

Capacitors

<u>Circuit Ref.</u>	<u>Value</u>	<u>Rating V</u>	<u>Tol. %</u>	<u>Manufacturer</u>	<u>Type</u>	<u>Part No.</u>
C15	25µF	300	-10 +50	Philips	Electrolyt	40903
C16	25µF	300	-10 +50	Philips	Electrolyt	40903
C17	25µF	300	-10 +50	Philips	Electrolyt	40903
C18	220pF	500	10	Philips	Ceramic	40100
C19	220pF	500	10	Philips	Ceramic	40100
C20	10nF	500	-20 +50	Philips	Ceramic	40160
C21	220pF	500	10	Philips	Ceramic	40100
C22	0,1µF	400	20	Philips	Metall.plastic	40730
C23	10nF	500	-20 +50	Philips	Ceramic	40160
C24	0,1µF	400	20	Philips	Metall.plastic	40730
C25	10nF	500	-20 +50	Philips	Ceramic	40160
C26	0,1µF	400	20	Philips	Metall.plastic	40730
C27	200-1000pF			Bulgin	Mica Pre-set	41050

A/s DANBRIDGE

47 Brigadevej . Copenhagen S . Denmark

Resistors

<u>Circuit Ref.</u>	<u>Value</u>	<u>Rating</u>	<u>Tol. %</u>	<u>Manufacturer</u>	<u>Type</u>	<u>Part No.</u>
R23	10kΩ	1/3W	5	Beyschlag	Carbon	43310
R24	10kΩ	1/3W	5	Beyschlag	Carbon	43310
R25	2.2kΩ	1/3W	5	Beyschlag	Carbon	43222
R26	100kΩ	1/3W	5	Beyschlag	Carbon	43410
R27	1MΩ	1/3W	5	Beyschlag	Carbon	43510
R28	220kΩ	1/3W	5	Beyschlag	Carbon	43422
R29	100kΩ	1/3W	5	Beyschlag	Carbon	43410
R30	1MΩ	1/3W	5	Beyschlag	Carbon	43510
R31	100kΩ	1/3W	5	Beyschlag	Carbon	43410
R32	10kΩ	1/3W	5	Beyschlag	Carbon	43310
R33	33kΩ	1/3W	5	Beyschlag	Carbon	43333
R34	2.2kΩ	1/3W	5	Beyschlag	Carbon	43222
R35	2.2kΩ	1/3W	5	Beyschlag	Carbon	43222
R36	1MΩ	1/3W	5	Beyschlag	Carbon	43510
R37	2.2kΩ	1/3W	5	Beyschlag	Carbon	43222
R39	1MΩ	1/3W	5	Beyschlag	Carbon	43510

Miscellaneous

Part No.

L2 Tuning coil, Danbridge	92530
V4, V5, V6 Pentode tube EF86, Philips, Mullard	54200
VDR2 Voltage dependent resistor type E299DD/P30 Philips, Mullard	46000
3-Noval tube sockets, manufacturer Jungbecker	25403

4. FRONT PANEL COMPONENTS

<u>Circuit Ref.</u>	<u>Part No.</u>
M1 Moving coil meter 95μA "kV" Manufacturer Jensen Electric	42655
M2 Moving coil meter 100μA "μA" Manufacturer Jensen Electric	42656
Printed circuit board on M1 complete	89053
Components mounted on above board	
R19 Resistor, carbon adjusted on test	
R20 Resistor, carbon 100kΩ 1/3W 5% Beyschlag	43410
R21 Resistor, carbon 100kΩ 1/3W 5% Beyschlag	43410

Printed circuit board on M2 complete	Part No. 89054
Components mounted on above board	
R22 Resistor carbon 1k Ω 1/3W 5% Beyschlag	Part No. 43210
Rec.2. Silicon diode OA202, Philips, Mullard	Part No. 26150
PI1 Pilot lampholder red Bulgin	Part No. 41202
Pilot lamp Philips 6.3V/0.3A	Part No. 33570
PI2 Pilot lampholder green Bulgin	Part No. 41203
Pilot lamp Philips 6.3V/0.3A	Part No. 33570
Sw.1 DPST Switch "6/12kV" Torotex	Part No. 20080
Sw.4 DPST Switch "Power" Torotex	Part No. 20080
R38 Potentiometer "Gain", Carbon, 1M Ω , log. Ruwido	Part No. 51590
R10 Potentiometer "H.T. Control" WW 100k Ω 4W Colvern	Part No. 51580
R9 Resistor, Carbon 82k Ω , 1W, 5%, Beyschlag (Mounted on SW1)	Part No. 45382
CL3 Capacitor, oil, 5nF/2kV Jensen	Part No. 40420
VDRL Voltage dependent resistor E298 ZZ/06 (CL3 & VDRL mounted on SW.4)	Part No. 46001
Phone socket, 3 pole socket	Part No. 25015
Ext. H.T. switch socket, 4 pole socket	Part No. 25017
Loudspeaker crystal type	Part No. 34601
Knob for Gain & H.T. Control	Part No. 38103

5. REAR PANEL COMPONENTS

Circuit Ref.

T3 Power Transformer, Manufacture J.S.	Part No. 61003
SW.3 Voltage switch, Manufacture Schurter	Part No. 57800
Fuse Holder, manufacture TS	Part No. 55900
Fuse 5 x 20mm, slow (115V : 1A	Part No. 55914
(230V : 0.5A	Part No. 55912
Power Socket	Part No. 25000

6. TEST PROD AND MISCELLANEOUS

Test prod complete with cable	Part No. 93160
Mains lead with chassis plug	Part No. 87160
Plug connector for phone	Part No. 25016
Plug connector for Ext. H.T. switch	Part No. 25018